

# Missouri Department of Natural Resources



## PUBLIC NOTICE

### APPLICATION FOR MISSOURI STATE OPERATING PERMIT

DATE: August 4, 2006

In accordance with the state Clean Water Law, Chapter 644, RSMo, Clean Water Commission regulation 10 CSR 20-6.010, and the federal Clean Water Act, the applicants listed herein have applied for authorization to either discharge to waters of the state or to operate a no-discharge wastewater treatment facility. The proposed permits for these operations are consistent with applicable water quality standards, effluent standards and/or treatment requirements or suitable timetables to meet these requirements (see 10 CSR 20-7.015 and 7.031). All permits will be issued for a period of five years, unless noted otherwise in the Public Notice for that discharge.

On the basis of preliminary staff review and the application of applicable standards and regulations, the Missouri Department of Natural Resources, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions. The proposed determinations are tentative pending public comment.

Persons wishing to comment on the proposed effluent limitations and/or determinations are invited to submit them in writing to the Department of Natural Resources, Southwest Regional Office, Water Pollution Unit, 2040 W. Woodland, Springfield, Missouri 65807, ATTN: Cynthia S. Davies, Regional Director. Please include the permit number in all comment letters.

Comments should be confined to the issues relating to the proposed action and permit(s) and the effect on water quality. The department may not consider as relevant comments or objections to a permit based on issues outside the authority of the Clean Water Commission, (see Curdt v. Mo. Clean Water Commission, 586 S.W.2d 58 Mo. App. 1979).

All comments must be postmarked by September 3, 2006 or received in our office by 5:00 p.m. on September 6, 2006. The requirement of a signed document makes it impossible to accept email comments for consideration at this time. Comments will be considered in the formulation of all final determinations regarding the applications. If response to this notice indicates significant public interest, a public meeting or hearing may be held after due notice for the purpose of receiving public comment on the proposed permit or determination. Public hearings and/or issuance of the permit will be conducted or processed according to 10 CSR 20-6.020.

Copies of all draft permits, comments, and other information including copies of applicable regulations are available for inspection and copying at the department's website, <http://www.dnr.mo.gov/env/wpp/wpcp-pn.htm> or at the Department of Natural Resources, Southwest Regional Office, Water Pollution Unit, 2040 W. Woodland, Springfield, Missouri 65807, between the hours of 8:00 a.m. and 5:00 p.m., Monday through Friday.


Public Notice Date: August 4, 2006

Permit Number: MO-0094927

Southwest Regional Office

<b>FACILITY NAME AND ADDRESS</b>	<b>NAME AND ADDRESS OF OWNER</b>
Versailles WWTF 1000 Gunn Road Versailles, MO 65084	City of Versailles 104 N. Fisher Street Versailles, MO 65084
<b>RECEIVING STREAM &amp; LEGAL DESCRIPTION</b>	<b>TYPE OF DISCHARGE</b>
Unnamed Tributary to Straight Fork NE¼, SE¼, Sec. 36, T43N, R18W Morgan County	Domestic, reissuance

STATE OF MISSOURI  
**DEPARTMENT OF NATURAL RESOURCES**  
MISSOURI CLEAN WATER COMMISSION



## MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended.

Permit No. MO-0094927

Owner: City of Versailles  
Address: 104 N. Fisher Street, Versailles, MO 65084

Continuing Authority: Same as above  
Address: Same as above

Facility Name: Versailles WWTF  
Facility Address: 1000 Gunn Road, Versailles, MO 65084

Legal Description: NE¼, SE¼, Sec. 36, T43N, R18W, Morgan County  
Receiving Stream: Unnamed Tributary to Straight Fork (U)  
First Classified Stream and ID: Straight Fork (C) (00959) 303(d)  
USGS Basin & Sub-watershed No.: (10300102-200001)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

### **FACILITY DESCRIPTION**

Outfall #001 - POTW - SIC #4952

Oxidation ditch / sludge storage lagoon / sludge is being land applied.

Design organic population equivalent is 5,500.  
Design average daily flow is 550,000 gallons per day.  
Design sludge production is 50.5 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

\_\_\_\_\_  
Effective Date

\_\_\_\_\_  
Doyle Childers, Director, Department of Natural Resources  
Executive Secretary, Clean Water Commission

\_\_\_\_\_  
Expiration Date  
MO 780-0041 (10-93)

\_\_\_\_\_  
Cynthia S. Davies, Regional Director, Southwest Regional Office

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS				PAGE NUMBER 2 of 11		
				PERMIT NUMBER MO-0094927		
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The interim effluent limitations shall become effective upon issuance and remain in effect until <b>September 30, 2009</b> . Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	INTERIM EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<b>Outfall #001</b>						
Flow	GPD	*		*	once/week**	24 hr. total
Biochemical Oxygen Demand <sub>5</sub> ***	mg/L		45	30	once/month**	24 hr. composite
Total Suspended Solids***	mg/L		45	30	once/month**	24 hr. composite
pH – Units	SU	****		****	once/month**	grab
Fecal Coliform (Note 1)	#/100 ml	*		*(Note 2)	once/month**	grab
Zinc, Total Recoverable	mg/L	*		*	once/month**	grab
Chromium III, Total Recoverable	mg/L	*		*	once/month**	grab
Chromium IV, Total Recoverable	mg/L	*		*	once/month**	grab
Chloride	mg/L	*		*	once/month**	grab
Ammonia as N	mg/L	*		*	once/month**	grab
Temperature	°C	*		*	once/month**	grab
Oil & Grease	mg/L	*		*	once/month**	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
Whole Effluent Toxicity (Wet) Test	% Survival	(See Special Conditions)			twice/per permit cycle in <b>2008 &amp; 2010</b>	24 hr. composite
MONITORING REPORTS SHALL BE SUBMITTED <u>TWICE PER PERMIT CYCLE</u> ; THE FIRST REPORT IS DUE <u>OCTOBER 28, 2007</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<b>Outfall #002</b>						
Flow	GPD				once/discharge/day	24 hr. estimate
Biochemical Oxygen Demand <sub>5</sub>	mg/L		45		once/discharge/day	grab
Total Suspended Solids	mg/L		45		once/discharge/day	grab
pH – Units	SU	****		****	once/discharge/day	grab
Ammonia as N	mg/L	*		*	once/discharge/day	grab
Temperature	°C	*		*	once/discharge/day	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)					PAGE NUMBER 3 of 11	
PERMIT NUMBER MO-0094927						
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The interim effluent limitations shall become effective <b>October 1, 2009</b> and remain in effect until <b>July 31, 2011</b> . Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	INTERIM EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	GPD	*		*	once/week**	24 hr. total
Biochemical Oxygen Demand <sub>5</sub> ***	mg/L		45	30	once/month**	24 hr. composite
Total Suspended Solids***	mg/L		30	15	once/month**	24 hr. composite
pH – Units	SU	****		****	once/month**	grab
Fecal Coliform (Note 1)	#/100 ml	*		*(Note 2)	once/month**	grab
Zinc, Total Recoverable	mg/L	0.17		0.084	once/month**	grab
Chromium III, Total Recoverable	mg/L	0.20		0.098	once/month**	grab
Chromium IV, Total Recoverable	mg/L	0.015		0.0076	once/month**	grab
Chloride	mg/L	376		188	once/month**	grab
Ammonia as N	mg/L				once/month**	grab
(June 1 – August 31)		3.2		1.6		
(September 1 – November 30)		6.8		3.4	once/month**	grab
(December 1 – February 29)		7.5		3.8		
(March 1 – May 31)		6.8		3.4		
Oil & Grease	mg/L	15		10	once/month**	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
Whole Effluent Toxicity (Wet) Test	% Survival	(See Special Conditions)			twice/per permit cycle in <b>2008 &amp; 2010</b>	24 hr. composite
MONITORING REPORTS SHALL BE SUBMITTED <u>TWICE PER PERMIT CYCLE</u> ; THE FIRST REPORT IS DUE <u>OCTOBER 28, 2007</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<u>Outfall #002</u>						
Flow	GPD				once/discharge/day	24 hr. estimate
Biochemical Oxygen Demand <sub>5</sub>	mg/L		45		once/discharge/day	grab
Total Suspended Solids	mg/L		45		once/discharge/day	grab
pH – Units	SU	****		****	once/discharge/day	grab
Ammonia as N	mg/L	*		*	once/discharge/day	grab
Temperature	°C	*		*	once/discharge/day	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)					PAGE NUMBER 4 of 11	
					PERMIT NUMBER MO-0094927	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective <b>August 1, 2011</b> and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	GPD	*		*	once/week**	24 hr. total
Biochemical Oxygen Demand <sub>5</sub> ***	mg/L		45	30	once/month**	24 hr. composite
Total Suspended Solids***	mg/L		30	15	once/month**	24 hr. composite
pH – Units	SU	****		****	once/month**	grab
Fecal Coliform (Note 1)	#/100 ml	1000		400 (Note 2)	once/month**	grab
Zinc, Total Recoverable	mg/L	0.17		0.084	once/month**	grab
Chromium III, Total Recoverable	mg/L	0.20		0.098	once/month**	grab
Chromium IV, Total Recoverable	mg/L	0.015		0.0076	once/month**	grab
Chloride	mg/L	376		188	once/month**	grab
Ammonia as N	mg/L				once/month**	grab
(June 1 – August 31)		3.2		1.6		
(September 1 – November 30)		6.8		3.4	once/month**	grab
(December 1 – February 29)		7.5		3.8		
(March 1 – May 31)		6.8		3.4		
Oil & Grease	mg/L	15		10	once/month**	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
Whole Effluent Toxicity (Wet) Test	% Survival	(See Special Conditions)			twice/per permit cycle in <b>2008 &amp; 2010</b>	24 hr. composite
MONITORING REPORTS SHALL BE SUBMITTED <u>TWICE PER PERMIT CYCLE</u> ; THE FIRST REPORT IS DUE <u>OCTOBER 28, 2007</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<u>Outfall #002</u>						
Flow	GPD				once/discharge/day	24 hr. estimate
Biochemical Oxygen Demand <sub>5</sub>	mg/L		45		once/discharge/day	grab
Total Suspended Solids	mg/L		45		once/discharge/day	grab
pH – Units	SU	****		****	once/discharge/day	grab
Ammonia as N	mg/L	*		*	once/discharge/day	grab
Temperature	°C	*		*	once/discharge/day	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<b>B. STANDARD CONDITIONS</b>						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, II &amp; III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- \* Monitoring requirement only.
- \*\* Reports shall be submitted by the 28<sup>th</sup> day of the month following the reporting period, e.g. Reporting period is the month of March (samples collected weekly an monthly), report due by April 28<sup>th</sup>.
- \*\*\* This facility is required to provide a 30-day average percent removal of at least 85%.
- \*\*\*\* pH is measured in pH units and is not to be averaged. The pH for all facilities except lagoons is limited to the range of 6.0-9.0 pH units.

Note 1 - Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31.

Note 2 - Monthly average limit for Fecal Coliform is expressed as a geometric mean. Geometric mean for  
 $n \text{ samples} = [a_1 \times a_2 \times a_3 \dots \times a_n]^{1/n}$

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
  - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
    - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - (2) controls any pollutant not limited in the permit.
  - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
  - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.
4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
  - (1) One hundred micrograms per liter (100 µg/L);
  - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
  - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
  - (4) The level established in Part A of the permit by the Director.

C. SPECIAL CONDITIONS (continued)

- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.

5. Report as no-discharge when a discharge does not occur during the report period.

6. Water Quality Standards

- (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
- (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
  - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
  - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
  - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
  - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
  - (5) There shall be no significant human health hazard from incidental contact with the water;
  - (6) There shall be no acute toxicity to livestock or wildlife watering;
  - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
  - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities

- (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
- (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.

8. The permittee shall submit a report semi-annually with the Discharge Monitoring Reports (**on January 28 and July 28**) which addresses measures taken to locate and eliminate sources of inflow and infiltration into the City's collection system.



C. SPECIAL CONDITIONS (continued)

9. Whole Effluent Toxicity (WET) tests shall be conducted as follows

SUMMARY OF WET TESTING FOR THIS PERMIT				
OUTFALL	A.E.C. %	FREQUENCY	SAMPLE TYPE	MONTH

(a) Test Schedule and Follow-Up Requirements

- (1) Perform a single-dilution test in the months and at the frequency specified above. For tests which are successfully passed, submit test results using the department's WET test report form #MO-780-1899 along with complete copies of the test reports as received from the laboratory, including copies of chain-of-custody forms within 30 calendar days of availability to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102. If the effluent passes the test, do not repeat the test until the next test period.
  - a. For discharges of stormwater, samples shall be collected within three hours from when discharge first occurs.
  - b. Samples submitted for analysis of stormwater discharges shall be collected as a grab.
  - c. For discharges of non-stormwater, samples shall be collected only when precipitation has not occurred for a period of forty-eight hours prior to sample collection. In no event shall sample collection occur simultaneously with the occurrence of precipitation.
  - d. A twenty-four hour composite sample shall be submitted for analysis of non-stormwater discharges.
  - e. Upstream receiving water samples, where required, shall be collected upstream from any influence of the effluent where downstream flow is clearly evident.
  - f. Samples submitted for analysis of upstream receiving water may be collected as either a grab or twenty-four-hour composite as appropriate to the nature of the discharge.
  - g. Chemical and physical analysis of the upstream control and effluent sample shall occur immediately upon being received by the laboratory, prior to any manipulation of the effluent sample beyond preservation methods consistent with federal guidelines for WET testing that are required to stabilize the sample during shipping.
  - h. Any and all chemical or physical analysis of the effluent sample performed in conjunction with the WET test shall be performed at the 100% Effluent concentration in addition to analyses performed upon any other effluent concentration.
  - i. All chemical analyses included in the Missouri Department of Natural Resources WET test report form #MO-780-1899 shall be performed and results shall be recorded in the appropriate field of the report form.
  - j. Where flow-weighted composite sample is required for analysis, the samples shall be composited at the laboratory where the test is to be performed.
  - k. Where in stream testing is required downstream from the discharge, sample collection shall occur immediately below the established Zone of Initial Dilution in conjunction with or immediately following a release or discharge.
  - l. Samples submitted for analysis of downstream receiving water may be collected as either a grab or twenty-four-hour composite as appropriate to the nature of the discharge.
- (2) All failing test results along with complete copies of the test reports as received from the laboratory, including those tests conducted under condition (3) below, shall be reported to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the availability of the results.
- (3) If the effluent fails the test, a multiple dilution test shall be performed within 30 calendar days and biweekly thereafter, until one of the following conditions are met:
  - a. Three consecutive multiple-dilution tests pass. No further tests need to be performed until next regularly scheduled test period.
  - b. A total of three multiple-dilution tests fail.
- (4) Failure of at least three multiple-dilution tests during any period of accelerated monitoring violates the permit narrative requirement for aquatic life protection.

C. SPECIAL CONDITIONS (continued)

- (5) The permittee shall submit a CONCISE summary of all test results for the test series to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the third failed test.
  - (6) Additionally, the following shall apply upon failure of the third MULTIPLE DILUTION test: A toxicity identification evaluation (TIE) or toxicity reduction evaluation (TRE) is automatically triggered. The permittee shall contact THE WATER PROTECTION PROGRAM within 14 calendar days from availability of the test results to ascertain as to whether a TIE or TRE is appropriate. The permittee shall submit a plan for conducting a TIE or TRE to the WATER PROTECTION PROGRAM within 60 calendar days of the date of DNR's direction to perform either a TIE or TRE. This plan must be approved by DNR before the TIE or TRE is begun. A schedule for completing the TIE or TRE shall be established in the plan approval.
  - (7) Upon DNR's approval, the TIE/TRE schedule may be modified if toxicity is intermittent during the TIE/TRE investigations. A revised WET test schedule may be established by DNR for this period.
  - (8) If a previously completed TIE has clearly identified the cause of toxicity, additional TIEs will not be required as long as effluent characteristics remain essentially unchanged and the permittee is proceeding according to a DNR approved schedule to complete a TRE and reduce toxicity. Regularly scheduled WET testing as required in the permit, without the follow-up requirements, will be required during this period.
  - (9) When WET test sampling is required to run over one DMR period, each DMR report shall contain a copy of the department's WET test report form that was generated during the reporting period.
  - (10) Submit a concise summary in tabular format of all test results with the annual report.
- (b) PASS/FAIL procedure and effluent limitations:
- (1) To pass a single-dilution test, mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level;  $p = 0.05$ ) than that observed in the upstream receiving-water control sample. Where upstream receiving water is not available mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level;  $p = 0.05$ ) than that observed in the laboratory control. The appropriate statistical tests of significance shall be consistent with the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms or other federal guidelines as appropriate or required.
  - (2) To pass a multiple-dilution test:
    - a. For facilities with a computed percent effluent at the edge of the zone of initial dilution, Allowable Effluent Concentration (AEC), OF 30% OR LESS THE AEC must be less than three-tenths (0.3) of the  $LC_{50}$  concentration for the most sensitive of the test organisms; **OR**,
    - b. For facilities with an AEC greater than 30% the  $LC_{50}$  concentration must be greater than 100%; **AND**,
    - c. All effluent concentrations equal to or less than the AEC must be nontoxic. Mortality observed in all effluent concentrations equal to or less than the AEC shall not be significantly different (at the 95% confidence level;  $p = 0.05$ ) than that observed in the upstream receiving-water control sample. Where upstream receiving water is not available mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level;  $p = 0.05$ ) than that observed in the laboratory control. The appropriate statistical tests of significance shall be consistent with the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms or other federal guidelines as appropriate or required. Failure of one multiple-dilution test may be considered an effluent limit violation.
- (c) Test Conditions
- (1) Test Type: Acute Static non-renewal
  - (2) Test species: Ceriodaphnia dubia and Pimephales promelas (fathead minnow). Organisms used in WET testing shall come from cultures reared for the purpose of conducting toxicity tests and cultured in a manner consistent with the most current USEPA guidelines. All test animals shall be cultured as described in the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms.

C. SPECIAL CONDITIONS (continued)

- (3) Test period: 48 hours at the "Acceptable Effluent Concentration" (AEC) specified above.
- (4) When dilutions are required, upstream receiving stream water shall be used as dilution water. If upstream water is unavailable or if mortality in the upstream water exceeds 10%, "reconstituted" water will be used as dilution water. Procedures for generating reconstituted water will be supplied by the MDNR upon request.
- (5) Single-dilution tests will be run with:
  - a. Effluent at the AEC concentration;
  - b. 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
  - c. reconstituted water.
- (6) Multiple-dilution tests will be run with:
  - a. 100%, 50%, 25%, 12.5%, and 6.25% effluent, unless the AEC is less than 25% effluent, in which case dilutions will be 4 times the AEC, two times the AEC, AEC, 1/2 AEC and 1/4 AEC;
  - b. 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
  - c. reconstituted water.
- (7) If reconstituted-water control mortality for a test species exceeds 10%, the entire test will be rerun.
- (8) If upstream control mortality exceeds 10%, the entire test will be rerun using reconstituted water as the dilutant.

D. SCHEDULE OF COMPLIANCE

The new limits for **Ammonia as N, Total Recoverable Chromium III, Total Recoverable Chromium IV, Total Recoverable Zinc, Oil & Grease, Total Suspended Solids, and Chlorides** will go into effect on **October 1, 2009**. Prior to this date if construction is needed to meet the new limits then the following shall occur:

1. By April 30, 2007 submit a completed application for construction permit, application fee, and one copy each of an engineering report, plans and specifications prepared by a professional engineer registered in the State of Missouri to the Missouri Department of Natural Resources, 2040 West Woodland, Springfield, Missouri, 65807, for providing wastewater treatment facility improvements to comply with the final effluent limitations as list in Part A of this permit, designed in accordance with Missouri Clean Water Law Regulation 10 CSR 20 Chapter 8.
2. Within fifteen (15) calendar days of receipt of any request for additional information or changes in the engineering report, plans or specifications, respond and if necessary submit engineering modifications to the department.
3. Within 365 calendar days of issuance of the construction permit, construct the permitted wastewater treatment facility improvements.
4. Within fifteen (15) calendar days of completion of construction of wastewater treatment facility improvements, submit a Statement of Work Completed form, signed, sealed, and dated by a professional engineer registered in the State of Missouri certifying that the project has been completed substantially in accordance with the approved plans and specifications. In addition to the Statement of Work Completed, submit an application for a Missouri State Operating Permit modification complete with the appropriate modification fee to the Missouri Department of Natural Resources, 2040 West Woodland, Springfield, Missouri, 65807.

If you have questions you may contact the Missouri Department of Natural Resources, Southwest Regional Office by calling 417-891-4300 or by mail at 2040 West Woodland, Springfield, Missouri, 65807.

D. SCHEDULE OF COMPLIANCE (continued)

**For Fecal Coliform**

1. Submit a completed application for construction permit, application fee, and one copy each of an engineering report, plans and specifications prepared by a professional engineer registered in the State of Missouri to the Missouri Department of Natural Resources, 2040 West Woodland, Springfield, Missouri, 65807, for providing wastewater treatment disinfection improvements to comply with the final effluent limitations as list in Part A of this permit, designed in accordance with Missouri Clean Water Law Regulation 10 CSR 20 Chapter 8.
2. Within fifteen (15) calendar days of receipt of any request for additional information or changes in the engineering report, plans or specifications, respond and if necessary submit engineering modifications to the department.
3. Within 365 calendar days of issuance of the construction permit, construct the permitted wastewater treatment disinfection improvements.
4. Within fifteen (15) calendar days of completion of construction of wastewater treatment disinfection improvements, submit a Statement of Work Completed form, signed, sealed, and dated by a professional engineer registered in the State of Missouri certifying that the project has been completed substantially in accordance with the approved plans and specifications. In addition to the Statement of Work Completed, submit an application for a Missouri State Operating Permit modification complete with the appropriate modification fee to the Missouri Department of Natural Resources, 2040 West Woodland, Springfield, Missouri, 65807.
5. The entire project shall be completed by **August 1, 2011**.

If you have questions you may contact the Missouri Department of Natural Resources, Southwest Regional Office by calling 417-891-4300 or by mail at 2040 West Woodland, Springfield, Missouri, 65807.

DRAFT

## SUMMARY OF TEST METHODOLOGY FOR WHOLE-EFFLUENT TOXICITY TESTS

Whole-effluent-toxicity test required in NPDES permits shall use the following test conditions when performing single or multiple dilution methods. Any future changes in methodology will be supplied to the permittee by the Missouri Department of Natural Resources (MDNR). Unless more stringent methods are specified by the DNR, the procedures shall be consistent with the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms.

### Test conditions for Ceriodaphnia dubia:

Test duration:	48 h
Temperature:	25 ± 1°C Temperatures shall not deviate by more than 3°C during the test.
Light Quality:	Ambient laboratory illumination
Photoperiod:	16 h light, 8 h dark
Size of test vessel:	30 mL (minimum)
Volume of test solution:	15 mL (minimum)
Age of test organisms:	<24 h old
No. of animals/test vessel:	5
No. of replicates/concentration:	4
No. of organisms/concentration:	20 (minimum)
Feeding regime:	None (feed prior to test)
Aeration:	None
Dilution water:	Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness.
Endpoint:	Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at p ≤ 0.05)
Test acceptability criterion:	90% or greater survival in controls

### Test conditions for Pimephales promelas:

Test duration:	48 h
Temperature:	25 ± 1°C Temperatures shall not deviate by more than 3°C during the test.
Light Quality:	Ambient laboratory illumination
Photoperiod:	16 h light/ 8 h dark
Size of test vessel:	250 mL (minimum)
Volume of test solution:	200 mL (minimum)
Age of test organisms:	1-14 days (all same age)
No. of animals/test vessel:	10
No. of replicates/concentration:	4 (minimum) single dilution method 2 (minimum) multiple dilution method
No. of organisms/concentration:	40 (minimum) single dilution method 20 (minimum) multiple dilution method
Feeding regime:	None (feed prior to test)
Aeration:	None, unless DO concentration falls below 4.0 mg/L; rate should not exceed 100 bubbles/min.
Dilution water:	Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness.
Endpoint:	Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at p ≤ 0.05)
Test Acceptability criterion:	90% or greater survival in controls



**Missouri Department of Natural Resources**  
**Southwest Regional Office**  
**NPDES PERMITS AND ENGINEERING SECTION**

## Water Quality Review Sheet

Determination of Effluent Limits

### Facility Information

FACILITY NAME: Versailles WWTF NPDES #: MO-0094927

FACILITY TYPE/DESCRIPTION: POTW / Oxidation ditch/sludge storage lagoon/sludge is land applied. Outfall #002 is infiltration/inflow basin

ECOREGION: Ozark / Moreau 8- DIGIT HUC: 10300102 COUNTY: Morgan  
Central Irregular Plains Interior River Valleys and Hills Ozark Highlands  
Mississippi Alluvial & Loess Plains Western Corn Belt Plains

LEGAL DESCRIPTION: NE1/4, SE1/4, Sec. 36, T43N, R18W LATITUDE/LONGITUDE: #001:+3826295/-09251204  
#002:+3826308/-09251157

WATER QUALITY HISTORY: In compliance with previous limits for outfall 001, several exceedences for TSS at outfall 002.

### Outfall Characteristics

OUTFALL	DESIGN FLOW (CFS)	TREATMENT TYPE	RECEIVING WATERBODY	OTHER
001	0.85	Secondary	Unnamed tributary to Straight Fork	
002	0.23	Primary	Unnamed tributary to Straight Fork	

### Receiving Waterbody Information

WATERBODY	CLASS	WBID	1Q10 (CFS)	7Q10 (CFS)	30Q10 (CFS)	*DESIGNATED USES
Unnamed tributary to Straight Fork	U	----	0.0	0.0	0.0	General Criteria
Straight Fork	C	0959	0.0	0.0	0.1	AQL, LWV, WBC

\*Cool Water Fishery (CLF), Cold Water Fishery (CDF), Irrigation (IRR), Industrial (IND), Boating & Canoeing (BTG), Drinking Water Supply (DWS), Whole Body Contact Recreation (WBC), Protection of Warmwater Aquatic Life and Human Health (AQL), Livestock & Wildlife Watering (LWW)

COMMENTS: This water quality review sheet is a revision of the May 30, 2006 water quality review sheet. Approximately .25 miles to the classified section of Straight Fork The stream has been impacted with chlorides. According to ESP from 2003 through 2006 there have been ten occasions when the chronic chloride water quality standard has been exceeded in the classified portion of the receiving stream. Straight Fork is on the 303(d) list for Volatile Suspended Solids. The Water Quality Monitoring & Assessment Section has provided Wasteload Allocations for this facility to alleviate the pollution. This facility is the sole source of pollution that puts Straight Fork on the 303(d) list.

## MIXING CONSIDERATIONS

**Mixing Zone (MZ).** Not allowed. 10 CSR 20-7.031(4)(A)4.B.(I)(a)

**Zone of Initial Dilution (ZID).** Not allowed. 10 CSR 20-7.031(4)(A)4.B.(I)(b)

	Flow (cfs)	MZ (cfs)	ZID (cfs)
<u>1Q10</u>	<u>0.0</u>	0.0	0.0
<b>7Q10</b>	0.0	0.0	0.0
<b>30Q10</b>	0.0	0.0	N/A

## Permit Limits And Information

TMDL  
WATERSHED:  
(Y OR N)

☐ Y W.L.A. STUDY  
CONDUCTED:  
(Y OR N)

☐ Y DISINFECTION  
REQUIRED:  
(Y OR N)

☐ Y USE ATTAINABILITY  
ANALYSIS (Y,N)

☐ N

## OUTFALL# 001

WET TEST (Y OR N): ☐ Y FREQUENCY: ONCE/YEAR A.E.C. 100% LIMIT: 10 CSR 20-7.031(3)(I)2.

A.E.C. % = ( Design Flow + Zone of Initial Dilution / Design Flow )

PARAMETER	UNITS	MAXIMUM DAILY LIMIT	WEEKLY AVERAGE LIMIT	AVERAGE MONTHLY LIMIT	MONITORING FREQUENCY
FLOW		MONITOR		MONITOR	DAILY
BIOCHEMICAL OXYGEN DEMAND (BOD <sub>5</sub> )	mg/L		45	30	ONCE/MONTH
TOTAL SUSPENDED SOLIDS	mg/L		30	15	ONCE/MONTH
pH	SU	6-9		6-9	ONCE/MONTH
AMMONIA AS N (JUN 1 – AUG 31)	mg/L	3.2		1.6	ONCE/MONTH
AMMONIA AS N (SEP 1 – NOV 30)	mg/L	6.8		3.4	ONCE/MONTH
AMMONIA AS N (DEC 1 – FEB 29)	mg/L	7.5		3.8	ONCE/MONTH
AMMONIA AN N (MAR 1 – MAY 31)	mg/L	6.8		3.4	ONCE/MONTH
OIL & GREASE	mg/L	15		10	ONCE/MONTH
FECAL COLIFORM	NOTE 1	1000		400	ONCE/MONTH
TOTAL RESIDUAL CHLORINE	mg/L	0.017		0.0082	ONCE/MONTH
CHLORIDE	mg/L	376		188	ONCE/MONTH
CHROMIUM III, TOTAL RECOVERABLE	mg/L	0.20		0.098	ONCE/MONTH
CHROMIUM VI, TOTAL RECOVERABLE	mg/L	0.015		0.0076	ONCE/MONTH
ZINC, TOTAL RECOVERABLE	mg/L	0.17		0.084	ONCE/MONTH

NOTE 1 – COLONIES/100 mL,

## OUTFALL# 002

WET TEST (Y OR N): N FREQUENCY: \_\_\_\_\_ A.E.C. \_\_\_\_\_ LIMIT: \_\_\_\_\_

PARAMETER	UNITS	MAXIMUM DAILY LIMIT	WEEKLY AVERAGE LIMIT	AVERAGE MONTHLY LIMIT	MONITORING FREQUENCY
FLOW		MONITOR		MONITOR	DAILY
BIOCHEMICAL OXYGEN DEMAND (BOD <sub>5</sub> )	mg/L		45		ONCE/DISCHARGE/DAY
TOTAL SUSPENDED SOLIDS	mg/L		45		ONCE/DISCHARGE/DAY
PH	SU	6-9		6-9	ONCE/DISCHARGE/DAY
AMMONIA AS N	mg/L	MONITOR		MONITOR	ONCE/DISCHARGE/DAY

### Derivation and Discussion of Limits

Wasteload allocations (WLA) were calculated using water quality criteria and the dilution equation below:

$$C = \frac{(C_s * Q_s) + (C_e * Q_e)}{(Q_e + Q_s)} \quad (\text{EPA/505/2-90-001, Section 4.5.5})$$

Where C = downstream concentration

C<sub>s</sub> = upstream concentration

Q<sub>s</sub> = upstream flow (cfs)

C<sub>e</sub> = effluent concentration

Q<sub>e</sub> = effluent flow (cfs)

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ). Acute wasteload allocations were determined using applicable acute water quality criteria (CMC: criteria maximum concentration) and stream volume of flow.

Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA's "Technical Support Document For Water Quality-based Toxics Control" (EPA/505/2-90-001).

The C<sub>s</sub> is zero therefore C<sub>e</sub> will equal the WLA<sub>a</sub> or WLA<sub>c</sub> as demonstrated with the Ammonia parameter.

### OUTFALL 001

- **Biochemical Oxygen Demand** 10 CSR 20-7.015(8)(B)1.
- **Total Suspended Solids** A wasteload allocation study has been conducted for this facility. A steady-state water quality model (QUAL2K) was constructed and calibrated from this data and used to determine a TSS wasteload allocation (WLA) protective of water quality in Straight Fork. The WLA is treated as a not-to-be-exceeded limit.

WLA= 30mg/L

MDL= 30 mg/L, AML=15 mg/L

- **pH.** pH shall be maintained in the range from six to nine (6 – 9) standard units [10 CSR 20-7.015(8)(B)2.].
- **Ammonia as Nitrogen.** Total Ammonia Nitrogen – Early Life Stages Present criteria apply 10 CSR 20-7.031(4)(B)7.C. & Table B3. Background ammonia as nitrogen for receiving stream is assumed to be = 0.01mg/L.



Season	Temp (°C)	pH (SU)	Total Ammonia Nitrogen CCC (mg/L)	Total Ammonia Nitrogen CMC (mg/L)
Summer	28	7.8	1.3	12.1
Fall	16	7.8	2.8	12.1
Winter	6	7.8	3.1	12.1
Spring	16	7.8	2.8	12.1

Summer: June 1 – August 31, Fall: September 1 – November 30, Winter: December 1 – February 29, Spring: March 1 – May 31.

$$C_e = ((Q_e + Q_s)C - (Q_s * C_s))/Q_e$$

**Spring** – Chronic WLA = 2.8 mg N/L, Acute WLA = 12.1 mg N/L. No mixing zone is allowed.

Chronic

$$C_e = ((0.85 + 0.0)2.8 - (0.0 * 0.01))/0.85$$

$$C_e = 2.8 \text{ mg/L}$$

$$WLA_c = 2.8 \text{ mg/L}$$

Acute

$$C_e = ((0.85 + 0.0)12.1 - (0.0 * 0.01))/0.85$$

$$C_e = 12.1 \text{ mg/L}$$

$$WLA_a = 12.1 \text{ mg/L}$$

$$LTA_c = 2.8 \text{ mg/L (0.780)} = 2.2 \text{ mg N/L}$$

$$[CV = 0.6, 99^{\text{th}} \text{ Percentile, } n = 30]$$

$$LTA_a = 12.1 \text{ mg/L (0.321)} = 3.9 \text{ mg N/L}$$

$$[CV = 0.6, 99^{\text{th}} \text{ Percentile}]$$

Use most protective number of  $LTA_c$  or  $LTA_a$ .

$$MDL = 2.2 \text{ mg/L} * 3.11 = 6.8 \text{ mg N/L}$$

$$[CV = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$AML = 2.2 \text{ mg/L} * 1.55 = 3.4 \text{ mg N/L}$$

$$[CV = 0.6, 95^{\text{th}} \text{ Percentile, } n = 4]$$

**Summer** – Chronic WLA = 1.3 mg N/L, Acute WLA = 12.1 mg N/L. No mixing zone is allowed.

Chronic

$$C_e = ((0.85 + 0.0)1.3 - (0.0 * 0.01))/0.85$$

$$C_e = 1.3 \text{ mg/L}$$

$$WLA_c = 1.3 \text{ mg/L}$$

Acute

$$C_e = ((0.85 + 0.0)12.1 - (0.0 * 0.01))/0.85$$

$$C_e = 12.1 \text{ mg/L}$$

$$WLA_a = 12.1 \text{ mg/L}$$

$$LTA_c = 1.3 \text{ mg/L (0.780)} = 1.014 \text{ mg N/L}$$

$$[CV = 0.6, 99^{\text{th}} \text{ Percentile, } n = 30]$$

$$LTA_a = 12.1 \text{ mg/L (0.321)} = 3.9 \text{ mg N/L}$$

$$[CV = 0.6, 99^{\text{th}} \text{ Percentile}]$$

Use most protective number of  $LTA_c$  or  $LTA_a$ .

$$MDL = 1.014 \text{ mg/L} * 3.11 = 3.2 \text{ mg N/L}$$

$$[CV = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$AML = 1.014 \text{ mg/L} * 1.55 = 1.6 \text{ mg N/L}$$

$$[CV = 0.6, 95^{\text{th}} \text{ Percentile, } n = 4]$$

**Fall** - Chronic WLA = 2.8 mg N/L, Acute WLA = 12.1 mg N/L. No mixing zone is allowed.

Chronic

$$C_e = ((0.85 + 0.0)2.8 - (0.0 * 0.01))/0.85$$

$$C_e = 2.8 \text{ mg/L}$$

$$WLA_c = 2.8 \text{ mg/L}$$

Acute

$$C_e = ((0.85 + 0.0)12.1 - (0.0 * 0.01))/0.85$$

$$C_e = 12.1 \text{ mg/L}$$

$$WLA_a = 12.1 \text{ mg/L}$$

$$LTA_c = 2.8 \text{ mg/L} (0.780) = 2.2 \text{ mg N/L}$$

$$[CV = 0.6, 99^{\text{th}} \text{ Percentile, } n = 30]$$

$$LTA_a = 12.1 \text{ mg/L} (0.321) = 3.9 \text{ mg N/L}$$

$$[CV = 0.6, 99^{\text{th}} \text{ Percentile}]$$

Use most protective number of  $LTA_c$  or  $LTA_a$ .

$$MDL = 2.2 \text{ mg/L} * 3.11 = 6.8 \text{ mg N/L}$$

$$[CV = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$AML = 2.2 \text{ mg/L} * 1.55 = 3.4 \text{ mg N/L}$$

$$[CV = 0.6, 95^{\text{th}} \text{ Percentile, } n = 4]$$

**Winter** – Chronic WLA = 3.1 mg N/L, Acute WLA = 12.1 mg N/L. No mixing zone is allowed.

Chronic

$$C_e = ((0.85 + 0.0)3.1 - (0.0 * 0.01))/0.85$$

$$C_e = 3.1 \text{ mg/L}$$

$$WLA_c = 3.1 \text{ mg/L}$$

Acute

$$C_e = ((0.85 + 0.0)12.1 - (0.0 * 0.01))/0.85$$

$$C_e = 12.1 \text{ mg/L}$$

$$WLA_a = 12.1 \text{ mg/L}$$

$$LTA_c = 3.1 \text{ mg/L} (0.780) = 2.4 \text{ mg N/L}$$

$$[CV = 0.6, 99^{\text{th}} \text{ Percentile, } n = 30]$$

$$LTA_a = 12.1 \text{ mg/L} (0.321) = 3.9 \text{ mg N/L}$$

$$[CV = 0.6, 99^{\text{th}} \text{ Percentile}]$$

Use most protective number of  $LTA_c$  or  $LTA_a$ .

$$MDL = 2.4 \text{ mg/L} * 3.11 = 7.5 \text{ mg N/L}$$

$$[CV = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$AML = 2.4 \text{ mg/L} * 1.55 = 3.7 \text{ mg N/L}$$

$$[CV = 0.6, 95^{\text{th}} \text{ Percentile, } n = 4]$$

Season	Maximum Daily Limit (mg/L)	Average Monthly Limit (mg/L)
Summer	3.2	1.6
Fall	6.8	3.4
Winter	7.5	3.8
Spring	6.8	3.4

- **Oil & Grease.** Conventional pollutant, effluent limitation for protection of aquatic life; 10 mg/L monthly average, 15 mg/L daily maximum.
- **Fecal Coliform** – Discharge shall not contain more than a monthly geometric mean of 400 colonies/ 100 mL and a daily maximum of 1000 colonies/100 mL during the recreational season (April 1 – October 31) [10 CSR 20-7.015(8)(B)4.A.] Future renewals of the facility operating permit will contain effluent limitations for E. coli which will replace fecal coliform as the applicable bacteria criteria in Missouri's water quality standards.
- **Total Residual Chlorine.** Warm water acute criteria = 19 g/L, warm water chronic criteria = 10 g/L [10 CSR 20-7.031,

Table A]. Background = 0.0 mg/L. No mixing zone allowed.

Chronic:  $C_e = WLA_c = 10 \text{ g/L}$

Acute:  $C_e = WLA_a = 19 \text{ g/L}$

$LTA_c = 10(0.527) = 5.3 \text{ g/L}$  [CV = 0.6, 99<sup>th</sup> Percentile]

$LTA_a = 19(0.321) = 6.1 \text{ g/L}$  [CV = 0.6, 99<sup>th</sup> Percentile]

Use most protective number of  $LTA_c$  or  $LTA_a$ . = 0.005 mg/L

$MDL = 5.3(3.11) = 16.5 \text{ g/L} = 0.017 \text{ mg/L}$  [CV = 0.6, 99<sup>th</sup> Percentile]

$AML = 5.3(1.55) = 8.2 \text{ g/L} = 0.082 \text{ mg/L}$  [CV = 0.6, 95<sup>th</sup> Percentile, n = 4]

- **Chloride** Protection of Aquatic Life CMC = 860 mg/L, CCC = 230 mg/L.

Chronic =  $C_e = WLA_c = 230 \text{ mg/L}$

Acute =  $C_e = WLA_a = 860 \text{ mg/L}$

$LTA_c = 230(0.527) = 121 \text{ mg/L}$  [CV = 0.6, 99<sup>th</sup> Percentile]

$LTA_a = 860(0.321) = 276 \text{ mg/L}$  [CV = 0.6, 99<sup>th</sup> Percentile]

Use most protective number of  $LTA_c$  or  $LTA_a$ .

$MDL = 121(3.11) = 376 \text{ mg/L}$  [CV = 0.6, 99<sup>th</sup> Percentile]

$AML = 121(1.55) = 188 \text{ mg/L}$  [CV = 0.6, 95<sup>th</sup> Percentile, n = 4]

**Reasonable Potential Analysis** Effluent limits for Chromium and Zinc have been retained as a result of the reasonable potential analyses. Electronic copies of the reasonable potential analyses are available upon request.

METAL	CMC ( g/L)	RECEIVING WATER CONCENTRATION ( g/L)	CCC ( g/L)	RECEIVING WATER CONCENTRATION ( g/L)	REASONABLE POTENTIAL
Chromium	794	174.1	103	174.1	Yes
Zinc	165	450.6	151	450.6	Yes

### **Metals**

Effluent limitations for total recoverable metals were developed using methods and procedures outlined in EPA/505/2-90-001 and “The Metals Translator: Guidance For Calculating A Total Recoverable Permit Limit From A Dissolved Criterion” (EPA 823-B-96-007). General warm-water fishery criteria apply and water hardness = 162.5 mg/L.

Due to the absence of contemporaneous effluent and instream data for total recoverable metals, dissolved metals, hardness, and total suspended solids with which to calculate metals translators, partitioning between the dissolved and absorbed phases was assumed to be minimal (Section 5.7.3, EPA/505/2-90-001). Freshwater criteria conversion factors for dissolved metals were used as the metals translator as recommended in guidance (Section 1.3, 1.5.3, and Table 1, EPA 823-B-96-007). If concurrent site-specific data for total recoverable metals, dissolved metals, hardness, and total suspended solids are provided to the department, partitioning evaluations may be considered and site-specific translators developed.

METAL	CONVERSION FACTORS
-------	--------------------

	ACUTE	CHRONIC
Chromium III	0.316	0.860
Chromium VI	0.982	0.962
Zinc	0.978	0.986

Values calculated using equation found in Section 1.3 of EPA 823-B-96-007 and hardness = 162.5 mg/L.

- **Total Recoverable Chromium III** Protection of Aquatic Life CMC = 794 g/L, CCC = 103 g/L. Background assumed to be = 0 g/L.

$$\begin{aligned}\text{Chronic} &= 103/0.860 = 120 \text{ g/L} \\ \text{Acute} &= 794/0.316 = 2513 \text{ g/L}\end{aligned}$$

$$\begin{aligned}\text{Chronic: } C_e &= WLA_c = 120 \text{ g/L} \\ \text{Acute: } C_e &= WLA_c = 2513 \text{ g/L}\end{aligned}$$

$$\begin{aligned}LTA_c &= 120(0.527)=63 \text{ g/L} & [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}] \\ LTA_a &= 2513(0.321)=807 \text{ g/L} & [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}]\end{aligned}$$

Use most protective number of  $LTA_c$  or  $LTA_a$ .

$$\begin{aligned}\text{MDL} &= 63(3.11)=196 \text{ g/L} = 0.20 \text{ mg/L} & [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}] \\ \text{AML} &= 63(1.55)=98 \text{ g/L} = 0.098 \text{ mg/L} & [\text{CV} = 0.6, 95^{\text{th}} \text{ Percentile, } n = 4]\end{aligned}$$

- **Total Recoverable Chromium VI** Protection of Aquatic Life CMC = 15 g/L, CCC = 10 g/L. Background assumed to be = 0 g/L.

$$\begin{aligned}\text{Chronic} &= 10/0.962 = 10.4 \text{ g/L} \\ \text{Acute} &= 15/0.982 = 15.3 \text{ g/L}\end{aligned}$$

$$\begin{aligned}\text{Chronic: } C_e &= WLA_c = 10.4 \text{ g/L} \\ \text{Acute: } C_e &= WLA_c = 15.3 \text{ g/L}\end{aligned}$$

$$\begin{aligned}LTA_c &= 10.4(0.527)=5.5 \text{ g/L} & [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}] \\ LTA_a &= 15.3(0.321)=4.9 \text{ g/L} & [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}]\end{aligned}$$

Use most protective number of  $LTA_c$  or  $LTA_a$ .

$$\begin{aligned}\text{MDL} &= 4.9(3.11)=15.2 \text{ g/L} = 0.015 \text{ mg/L} & [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}] \\ \text{AML} &= 4.9(1.55)=7.6 \text{ g/L} = 0.0076 \text{ mg/L} & [\text{CV} = 0.6, 95^{\text{th}} \text{ Percentile, } n = 4]\end{aligned}$$

- **Total Recoverable Zinc** Protection of Aquatic Life CMC = 165 g/L, CCC = 151 g/L. Background Total Recoverable Copper assumed to be = 0 mg/L.

$$\begin{aligned}\text{Chronic} &= 151/0.986 = 153 \text{ g/L} \\ \text{Acute} &= 165/0.978 = 169 \text{ g/L}\end{aligned}$$

Chronic:  $C_e = WLA_c = 153 \text{ g/L}$

Acute:  $C_e = WLA_c = 169 \text{ g/L}$

$LTA_c = 153(0.527) = 81 \text{ g/L}$  [CV = 0.6, 99<sup>th</sup> Percentile]

$LTA_a = 169(0.321) = 54 \text{ g/L}$  [CV = 0.6, 99<sup>th</sup> Percentile]

Use most protective number of  $LTA_c$  or  $LTA_a$ .

$MDL = 54(3.11) = 168 \text{ g/L} = 0.17 \text{ mg/L}$  [CV = 0.6, 99<sup>th</sup> Percentile]

$AML = 54(1.55) = 84 \text{ g/L} = 0.084 \text{ mg/L}$  [CV = 0.6, 95<sup>th</sup> Percentile, n = 4]

### Outfall 002

- **Biochemical Oxygen Demand and Total Suspended Solids** 10 CSR 20-7.015(8)(B)3.E.(I)
- **pH**. pH shall be maintained in the range from six to nine (6 – 9) standard units 10 CSR 20-7.015(8)(B)3.E.(II)
- **Ammonia as Nitrogen** Monitoring only required to determine contributions from this facility.

Reviewer: Kristen Pattinson

Date: July 11, 2006

Unit Chief: Gale Roberts, P.E.

Monitoring and effluent limits contained within this document have been developed in accordance with EPA guidelines using the best available data and are believed to be consistent with Missouri's Water Quality Standards and Effluent Regulations. If additional water quality data are available that may affect the recommended monitoring and effluent limits, please forward these data to the author.